

Chan, Janice

From: Sara Seuberling - AQDX
Sent: Tuesday, December 01, 2015 12:03 PM
To: Shannon Klimek - AQDX
Subject: RE: Permit 040136 - propane generator on site at water well at South Plant.

Follow Up Flag: Follow up
Flag Status: Flagged

I moved the engine to the deminimis list for Revision 2.0.2.0 but it remains in the permit so the Permittee knows that it is subject to Federal regulations. That is why engines smaller than 50 HP are still included in the emergency engine General Permit. From what I understand, MCAQD does not write violations for deminimis equipment.

From: Shannon Klimek - AQDX
Sent: Tuesday, December 01, 2015 12:58 PM
To: Sara Seuberling - AQDX
Subject: RE: Permit 040136 - propane generator on site at water well at South Plant.

I meant, Is this appropriate for permitting. Does this item need to be on the permit?

Apologies for the ambiguity.

Shannon.

From: Sara Seuberling - AQDX
Sent: Tuesday, December 01, 2015 12:50 PM
To: Shannon Klimek - AQDX
Subject: RE: Permit 040136 - propane generator on site at water well at South Plant.

Shannon,

My judgement is that the permit does not require a boilerplate to be present on the engine so it is not a violation as far as MCAQD is concerned. I wonder if the maintenance plan for the engine requires it be run periodically.

From: Shannon Klimek - AQDX
Sent: Tuesday, December 01, 2015 10:20 AM
To: Sara Seuberling - AQDX
Subject: Permit 040136 - propane generator on site at water well at South Plant.

Sara,

The site has a 5.5KW propane generator on site which is listed as permitted equipment. The boilerplate looks like it was torn off (IMG_1754). Is this appropriate? I could not verify the hours because the battery was dead, but it was logged in writing at 494.1.

[See my inspection photos., particularly IMG_1752 through IMG_1755.](#)

The Air Quality Department strives to provide excellent customer service to residents of Maricopa County.

How are we doing? [Send us your feedback.](#)

Sincerely,

Shannon Klimek

Air Quality Inspector, Badge #92

Maricopa County Air Quality Department

1001 N. Central Avenue, #125 | Phoenix, AZ 85004

Located at the Central Ave. & Roosevelt METRO stop

Cell 602.527.6288 | CleanAirMakeMore.com

